
REPORT ON DUST MONITORING

AT

GRANGEGORMAN CAMPUS CENTRAL & EAST QUAD,

DUBLIN 7

INTERIM DUST MONITORING REPORT 03-01

3rd April to 1st May 2018

Prepared by:

Glenside Environmental
Unit 18 Great Island Industrial Estate
Ballincollig,
Cork

Prepared for:

Sisk FCC GG PPP Joint Venture
Wilton Works
Naas Road
Clondalkin
Dublin 22

TABLE OF CONTENTS

	<u>PAGE</u>
1. SURVEY DETAILS	3
2. DUST MONITORING SURVEY	3
2.1.1. <i>Sources of dust deposition.....</i>	<i>3</i>
2.1.2. <i>Meteorological Conditions.....</i>	<i>3</i>
2.2. SAMPLING METHOD	3
2.2.1. <i>Sampling Locations.....</i>	<i>3</i>
3. RESULTS	4

1. SURVEY DETAILS

2. Dust Monitoring Survey

Glenside Environmental were commissioned by Sisk FCC GG PPP Joint Venture, to conduct dust monitoring during site development works at Grangegorman Campus Central & East Quad Dublin 7.

This report presents the results of dust monitoring at 3 locations, Location A; East Quad West Boundary Wall, Location B; Grangegorman Upper East Boundary Wall, and Location C; Grangegorman Upper North Boundary wall from 3rd April to 1st May 2018. The locations are illustrated in Figure 1.

2.1.1. Sources of dust deposition

Within the site and due to the open ground conditions and exposed surfaces, dust can result from sources such as truck movements within the site, and wind-blown dust from both outside and within.

2.1.2. Meteorological Conditions

Meteorological conditions significantly affect the level of dust emissions and the deposition downwind of the source. The most significant meteorological elements affecting dust deposition are rainfall and wind-speed. Rain helps suppress the generation of dust due to the cohesive nature of water between dust particles. Wind lifts up particles into the air and transports them downwind. The worst-case dust deposition conditions typically occur during dry conditions with strong winds.

2.2. Sampling Method

Total dust deposition was measured at the site using the Bergerhoff gauges specified in the German Engineering Institute VDI 2119 document entitled "*Measurement of Dustfall using the Bergerhoff Instrument (Standard Method)*."

The containers were analysed by Eurofins Laboratories, Glanmire, Cork for total dust. The liquid was evaporated in a drying chamber and the dustfall residue weighed using a calibrated balance. The daily dust deposition rate was then calculated using information on the dustfall mass, the sampling period and the area of the collecting surface.

2.2.1. Sampling Locations

The dust gauges were set up at the location selected at positions A B and C. The locations are shown in Figure 1. The gauges were erected such that the containers were 1.8m above the ground surface and free from any obstruction. The containers were exposed from 3rd April to 1st May 2018.

3. Results


Table 3.1 details the results of the dust monitoring.

Table 3.1: Results of dust deposition from 3rd April to 1st May 2018.

Location	Dust Level mg/m ² /day	Typical Limit mg/m ² /day
A (East Quad West Boundary)	95.8	350
B (Upper East Boundary Wall)	90.8	350
C (Upper North Boundary Wall)	68.4	350

The dust deposition results indicate the commonly applied figure of 350mg/m²/day was not exceeded at any of the 3 locations assessed. The highest levels recorded were at location A with a level of 95.8mg/m²/day.

Figure 1: Dust Monitoring Locations, A B and C.



APPENDIX I
LABORATORY REPORT

Client: Patrick Power
Glenside Environmental
Unit 18
Great Island Business Park
Ballincollig
Co. Cork
Ireland

Certificate No.: 2714821
Job Ref: 18E06686
Sample Ref No.: LSN 21/87373
Page No.: 1 of 3
Date Received: 01/05/2018
Date Reported: 22/05/2018

CERTIFICATE OF ANALYSIS

Dustjar - GG D1 - 03/04/2018 - 01/05/2018

Date Sampled:
Sample Type:

WATER - SURFACE WATER

Category: ENVIRO
Date Testing Initiated: 18/05/2018
Sample Condition: Satisfactory
Order No.: NA
Date Received: 01/05/2018

Test	Result	Unit	Method
* Dustfall Value (bergerhoff)	0.0958	g	ET2811

All tests are carried out according to our INAB schedule of accreditation unless marked. Tests marked * are not accredited.

Comments, opinions, grades and interpretations expressed herein are outside this current scope of INAB accreditation. The Laboratory has tested the material/items supplied by the customer as sampled in accordance with the customers own requirements.

Signed for and on behalf of Eurofins Food Testing Ireland Limited - Cork.



Michael Barry

B.Sc (Env. Science)
Snr.Tech Env. Services Division



Client: Patrick Power
Glenside Environmental
Unit 18
Great Island Business Park
Ballincollig
Co. Cork
Ireland

Certificate No.: 2714821
Job Ref: 18E06686
Sample Ref No.: LSN 21/87374
Page No.: 2 of 3
Date Received: 01/05/2018
Date Reported: 22/05/2018

CERTIFICATE OF ANALYSIS

Dustjar - GG D2 - 03/04/2018 - 01/05/2018

Date Sampled:
Sample Type: WATER - SURFACE WATER

Category: ENVIRO
Date Testing Initiated: 18/05/2018
Sample Condition: Satisfactory
Order No.: NA
Date Received: 01/05/2018

Test	Result	Unit	Method
* Dustfall Value (bergerhoff)	0.0908	g	ET2811

All tests are carried out according to our INAB schedule of accreditation unless marked. Tests marked * are not accredited.

Comments, opinions, grades and interpretations expressed herein are outside this current scope of INAB accreditation. The Laboratory has tested the material/items supplied by the customer as sampled in accordance with the customers own requirements.

Signed for and on behalf of Eurofins Food Testing Ireland Limited - Cork.



Michael Barry

B.Sc (Env. Science)
Snr.Tech Env. Services Division



Client: Patrick Power
Glenside Environmental
Unit 18
Great Island Business Park
Ballincollig
Co. Cork
Ireland

Certificate No.: 2714821
Job Ref: 18E06686
Sample Ref No.: LSN 21/87375
Page No.: 3 of 3
Date Received: 01/05/2018
Date Reported: 22/05/2018

CERTIFICATE OF ANALYSIS

Dustjar - GG D3 - 03/04/2018 - 01/05/2018

Date Sampled:
Sample Type: WATER - SURFACE WATER

Category: ENVIRO
Date Testing Initiated: 18/05/2018
Sample Condition: Satisfactory
Order No.: NA
Date Received: 01/05/2018

Test	Result	Unit	Method
* Dustfall Value (bergerhoff)	0.0684	g	ET2811

All tests are carried out according to our INAB schedule of accreditation unless marked. Tests marked * are not accredited.

Comments, opinions, grades and interpretations expressed herein are outside this current scope of INAB accreditation. The Laboratory has tested the material/items supplied by the customer as sampled in accordance with the customers own requirements.

Signed for and on behalf of Eurofins Food Testing Ireland Limited - Cork.



Michael Barry

B.Sc (Env. Science)
Snr.Tech Env. Services Division

